

Laramie County
Fireworks Stand Inspection

Date: 5/14/19

Planning / Zoning
310 West 19th St.
633-4303

Fire Warden
3962 Archer Parkway
633-4335

Environmental Health
100 Central Ave.
633-4090

Business name: Phantom Fireworks
Owner: Bruce S. Zoldan, Jerry Bostocky, Alan L. Zoldan
Address: 237 I-25 Service Road East, Cheyenne, WY 82007
Phone: 775-9954
Permit #: _____ Yearly: X Seasonal: _____ / _____
Open Close

A. Zoning Requirements:
CB zone: _____ Site plan: on file Site plan changes: _____
Admin approval: _____ Compliance Cert.: _____
Outside zoned boundaries: _____

B. Retail Sales permit #: 25002955

C. Sanitary Facilities:
1. Portable Toilets
a) Pumped and cleaned X
b) Licensed pumper X will be pumped Friday
c) Removed within 2 weeks of closing X next
Permanent Facilities X

D. Trash Containment
1. (1) metal trash container X
2. No fire danger or litter problem X WTS

E. Stand / Storage Location
1. 60 feet from property boundary (Grandfathered) X 30 ft per new regs
2. 150 feet from petroleum storage/gas pumps X

F. Entry / Exit Doors
1. Two (2) public access doors – Size – 3.0 feet wide by 6 feet 8 inches tall X
2. Separated from each other X
3. Doors swing to outside X
4. Clear of supplies / materials /etc X
5. Exit signs clearly visible above exit on interior X

G. Fire Extinguishers:

- 1. Two (2) 5lb. 2-A, 10 BC dry Chemical type
- 2. Displays current/dated inspection tag

X
X

H. Fluorescent bulb covers in place

N/A LED

I. Signage

- 1. No Smoking – displayed correctly
- 2. No Discharge – displayed correctly
- 3. Sale under age – displayed correctly
- 4. Extreme Danger – (if applicable)
- 5. No spray painted retail / safety signs

X
X
X
N/A
X

need to be changed to 500ft.

J. Storage units

- 1. Two (2) fire extinguishers
- 2. Locked when not occupied
- 3. 5th wheel pinned or tires removed
- 4. 75 feet from stand
(Grandfathered distance)

N/A
N/A
N/A
N/A
N/A

K. Grounds

- 1. Grass trimmed to height of 2" for 75 feet from stand
- 2. Clear of debris / trash
- 3. Defined parking

X
X
X

Comments:

New "No Discharge" signs need to be placed. The store manager said they will order and have the new signs in place in 2 weeks.

Date: 5/14/2019 Time: 3:30pm

Inspectors:

_____ (N/A)
Planning / Zoning

Ch. Howell
City / County Health

[Signature]
Fire Warden